


# CERTIFICATE

<b>Certificate holder</b>	<b>JUMO GmbH &amp; Co. KG</b> <b>Moritz-Juchheim-Str. 1</b> <b>36039 Fulda</b> <b>GERMANY</b>
<b>Product</b>	Temperature control and limiting devices for heat generating systems
<b>Type, Model</b>	EM-20..., EM-20-E... EM-30..., EM-30-E...
<b>Testing basis</b>	DIN EN 14597:2015-02 Certification scheme Temperature control and limiting devices for heat generating systems (2009-01)
<b>Mark of conformity</b>	
<b>Registration No.</b>	STW(STB)775 S
<b>Valid until</b>	2023-05-31
<b>Nutzungsrecht</b>	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.  See annex for further information.

# ANNEX

Page 1 of 1

<b>Certificate</b>	STW(STB)775 S dated 2018-05-30
<b>Technical Data</b>	See technical data sheet to the above mentioned registration number at <a href="http://www.dincertco.tuv.com">www.dincertco.tuv.com</a>  the Temperature control and limiting devices is suitable for  - Safety Temperature Monitor (STW) with the modes of action 2B, 2K, 2L, 2N, 2P
<b>Testing laboratory/ Inspection body</b>	TÜV SÜD Industrie Service GmbH Prüflabor für Kälte-, Klima- u. Wärmetechnik Ridlerstraße 65 80339 München GERMANY  TÜV NORD Systems GmbH & Co. KG Prüflab. für Feuerungsanlagen Am TÜV 1 30519 Hannover GERMANY
<b>Test report(s)</b>	C-T 1370-02/13 dated 2013-05-17 Ü 2188-06/14 dated 2014-11-10 Ü 2273-06/15 dated 2015-07-27 Ü 2371-06/16 dated 2016-09-26 Ü 2441-06/17 dated 2017-07-24 C-T 1370-03/18 dated 2018-04-04
<b>Remark(s)</b>	Based on the examination  DIN EN 60730-2-9:2011-07 DIN EN 60730-1:2012-10 DIN EN 60730-1:2017-05 DIN EN 60335-1:2012-10, paragraph 30

