

Certificate of Compliance

Certificate Number **20090505-E66358**
Report Reference **E66358, 2009 May 5**
Issue Date **2009 May 5**

Page 1 of 2



Issued to: **JUMO GMBH & CO KG**
MORITZ-JUCHHEIM-STRASSE 1
36039 FULDA GERMANY

This is to certify that representative samples of

TEMPERATURE-INDICATING AND REGULATING EQUIPMENT

Temperature thermostats, Type 603070 followed by 0001, 0002, 0007, 0020 or 0070, followed by 7 or 8, followed by three numbers, followed by additional suffixes.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.



Standard(s) for Safety:

UL 873 Temperature- Indicating and - Regulating Equipment
CSA- C22.2 No. 24 Temperature - Indicating and - Regulating Equipment

Additional Information:

See Addendum for Ratings

Only those products bearing the UL Recognized Component Marks for the U.S. and Canada should be considered as being covered by UL's Recognition and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Recognized Component Mark for the U.S. generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:  may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions. The UL Recognized Component Mark for Canada consists of the UL Recognized Mark for Canada:  and the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory.

Look for the UL Recognized Component Mark on the product

Issued by:
Ronald Thuinte, Project Engineer
Underwriters Laboratories Inc.

Reviewed by:
Diego Salmaso, Project Engineer
Underwriters Laboratories Inc.

