

# Certificate of Compliance

Certificate Number **20090610-E66358**  
Report Reference **E66358-2009 June 04**  
Issue Date **2009 June 10**

Page 1 of 2



*Issued to:* **JUMO GMBH & CO KG**  
MORITZ-JUCHHEIM-STRASSE 1  
36039 FULDA GERMANY

*This is to certify that representative samples of*

## **COMPONENT TEMPERATURE-INDICATING AND REGULATING EQUIPMENT**


Temperature thermostats, Type 603070 followed by four numbers, followed by 5 or 6, followed by three numbers, followed by additional suffixes.

*Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:* UL 873, the Standard for Temperature Indicating and Regulating Equipment, 12th edition  
Canadian Standard C22.2 No. 24-1993, the Standard for Temperature Indicating and Regulating Equipment, 8th edition.

*Additional Information:* See Addendum 1 for Electrical Ratings.

**Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.**

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

### **Look for the UL Listing Mark on the product**

Issued by:  
**Ronald Thuinte, Project Engineer**

UL International (Netherlands) B.V.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.  
For questions in Netherlands, you may call +31 (0)26 376 4800.

Reviewed by:  
**Eddie White, Staff Engineering Associate**

UL International (Netherlands) B.V.

# Certificate of Compliance

Certificate Number 20090610-E66358  
Report Reference E66358-2009 June 04  
Issue Date 2009 June 10

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## RATINGS:

Electrical - SPDT or SPST

Temperature Regulating thermostats, Model 603070 followed by 01xx, 02xx, 20xx, xx01, xx02, xx20

Snap Element	Contact	Amperage [A]	Inductive load	Voltage [V]	Number of operation
CuBe	NC (1-2)	16 res.	2.5 A	240 Vac	6000
CuBe	NO (1-4)	6.3 res.	2.5 A	240 Vac	6000
CuBe	all	0.25 A res	-	240 Vdc	6000

Temperature Limiting thermostats, Model 603070 followed by xx07, xx70, 07xx or 70xx

Snap Element	Contact	Amperage [A]	Inductive load	Voltage [V]	Number of operation
CuBe	NC (1-2)	16 res.	2.5 A	240 Vac	6000
CuBe	NO (1-4)	2 A res	0.4 A	240 Vac	6000
CuBe	all	0.25 A res	-	240 Vdc	6000

Issued by:

**Ronald Thuinte, Project Engineer**

UL International (Netherlands) B.V.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL/UL International (Netherlands) B.V.

Reviewed by:

**Eddie White, Staff Engineering Associate**

UL International (Netherlands) B.V.